



Water Quality Permitting Program Monitoring Matrix^{1,2,3,4}

Under 40 CFR 122.41(h) and OAR340-045-0015(5)(d) DEQ has the authority to require that permittees monitor and provide information. This matrix has been developed in coordination with internal and external DEQ stakeholders to assist the permit writer in identifying the appropriate pollutants and frequencies for monitoring in the permit. The recommended pollutants and frequencies are based on requirements from federal and state rules, best management practices, and best professional judgement.

Table 1 NPDES Domestic Treatment Facilities: Activated Sludge, Trickling Filter and Lagoon Treatment Facilities (effluent monitoring unless otherwise indicated, applies to all facilities unless otherwise indicated)				
PARAMETER	Units	AVERAGE DRY WEATHER DESIGN CAPACITY, MGD ⁵		
		Minor < 0.10 ⁶	Minor 0.10-1.00	Major >1.0
Total Flow (influent and/or effluent) ⁷	MGD	Daily, Metered		
BOD / CBOD ⁸ /TSS				
BOD and TSS: Activated Sludge/Trickling Filter (influent and effluent conc.)	mg/l	2/month, 24-hr composite	2/week, 24-hr composite	3/week, 24-hr composite
BOD and TSS: Activated Sludge/ Trickling Filter (lbs discharged)	lbs/day	2/ month, calculation	2/week, calculation	3/week, calculation
BOD and TSS: Lagoons (influent and effluent conc.)	mg/l	1/month, 24-hr composite	1/week, 24-hr composite	3/week, 24-hr composite
BOD and TSS: Lagoons (lbs discharged)	lbs/day	1/month, calculation	1/week, calculation	3/week, calculation
BOD and TSS Average % Removal Efficiency ⁹ : Activated Sludge/ Trickling Filter and Lagoons	Percentage (%)	Monthly, calculation		
Other Conventional Parameters				
pH (influent and effluent)	standard units	3/ week Grab		Daily, Grab or Continuous ¹⁰
Bacteria: <i>E. coli</i> , enterococcus, and/or fecal coliform ¹¹	# Org. /100mL or MPN/100 mL	2/ month Grab	2/week, Grab	3/week, Grab

Table 1 NPDES Domestic Treatment Facilities: Activated Sludge, Trickling Filter and Lagoon Treatment Facilities (effluent monitoring unless otherwise indicated, applies to all facilities unless otherwise indicated)				
PARAMETER	Units	AVERAGE DRY WEATHER DESIGN CAPACITY, MGD ⁵		
		Minor < 0.10 ⁶	Minor 0.10-1.00	Major >1.0
Effluent Temperature ¹²	°C	3/ week Grab, or Continuous		Daily, Continuous
NH ₃ -N for toxicity	mg/L	Not required	With limit:1/week, 24 hr composite Without limit: 1/month, 24 hr composite	With limit: 2/week ¹³ , 24 hr composite Without limit: 1/month, 24 hr composite
Alkalinity ¹⁴	mg/L	1/quarter, Grab		1/month, Grab
Disinfection: Chlorine – required only if Chlorine is used for disinfection				
Chlorine, Total Residual: Effluent	mg/L	Daily, Grab		Daily, Grab or Continuous
Chlorine Residual: Pre De-chlorination ¹⁵	mg/L	Daily, Grab		Daily, Grab or Continuous
Chlorine Used	lbs/day	Daily, Measurement		
Disinfection: UV – required only if UV used for disinfection				
UV Dose ¹⁶	mJ/cm ²	Daily average, calculation		
Pretreatment – required only when permit holder is under a formal pretreatment program.				
EPA's pretreatment POCs and any other pollutants identified by pretreatment coordinator (influent and effluent) ¹⁷	µg/L	Not Applicable		Major <5 MGD Semi-annual, on 3 consecutive days ¹⁸ , 24-hr composite Major >5MGD Quarterly, on 3 consecutive days ¹⁸ 24-hr composite
Biosolids and Recycled Water – See NPDES Permit Template for requirements.				
Receiving Water Monitoring- See NPDES Permit Template for requirements				
WET (Whole Effluent Toxicity) Testing				
WET Testing	--	Not applicable, unless toxics are known issue		4 per permit cycle, must be in conjunction with Tier I toxics monitoring ¹⁹
Toxics ²⁰ – See Permit Template, Schedule B for requirements.				

Table 1 NPDES Domestic Treatment Facilities: Activated Sludge, Trickling Filter and Lagoon Treatment Facilities (effluent monitoring unless otherwise indicated, applies to all facilities unless otherwise indicated)				
PARAMETER	Units	AVERAGE DRY WEATHER DESIGN CAPACITY, MGD ⁵		
		Minor < 0.10 ⁶	Minor 0.10-1.00	Major >1.0
Metals, Cyanide, and Hardness; Volatile Organic Compounds; Acid Extractable Compounds; and Base Neutral Compounds ²¹	µg/L unless otherwise specified	Not Applicable ²²		Characterization Monitoring: Quarterly for 3 years of permit cycle For pollutants with limits: 1/week, 24 hr composite or grab sample depending on parameter (Refer to Schedule B)
Pesticides and PCBs; and Other Parameters with State Water Quality Criteria ²³	µg/L unless otherwise specified	Not Applicable ²²		Characterization Monitoring: Quarterly for 1 year of permit cycle until 3 samples are collected For pollutants with limits: 1/week, 24 hr composite
Copper and Aluminum BLM	µg/L	Not Applicable ²²		Determined on case-by-case basis by Copper BLM Subject Matter Experts

Table 2 ²⁴ WPCF and NPDES Domestic Treatment Facilities Conventional Sand Filter and Recirculating Gravel Filter Treatment Facility Monitoring Requirements (effluent monitoring unless otherwise indicated)				
ITEM OR PARAMETER	WPCF FACILITIES		NPDES FACILITIES	
	≤ 30,000 GPD	> 30,000 GPD	≤ 30,000 GPD	> 30,000 GPD
Flow ⁷	Daily, Metered		Daily, Metered	
BOD / CBOD ⁸ /TSS				
BOD & TSS: Influent & Effluent	Quarterly Grab (influent)	Monthly Grab (influent)	Frequency for influent and effluent to be determined by design flow, see Table 1. Grab sample for systems ≤ 30,000 GPD; composite sample for ≥ 30,000 GPD.	
BOD & TSS Average % Removal Efficiency ^{9,25}	N/A	N/A	Monthly, Calculation	
pH	N/A	N/A	Frequency to be determined by design flow, see Table 1. Grab Sample.	
NH ₃ -N, NO ₃ +NO ₂ -N	Quarterly, Grab	Monthly, Grab	Quarterly, Grab	Monthly, Grab
TKN	Quarterly, Grab	Monthly, Grab	--	Monthly, Grab
<i>E. coli</i> bacteria	Not required for systems discharging to subsurface disposal.		Frequency to be determined by design flow, see Table 1. Grab sample.	
Chlorine Residual	Not required for systems discharging to subsurface disposal.		Daily, Grab	
Tank Inspection (Dosing, Septic & Recirculation)	Annual, Record observation		Annual, Record observation	
Inspect Grease Traps	Semi-annual, Record observation		Semi-annual, Record observation	
Inspect Pump Screens	Quarterly, Record observation		Quarterly, Record observation	
Depth of Effluent in Disposal Trench	Semi-annual ²⁶ , Measurement		N/A	

Table 3 WPCF Domestic Treatment Facilities Lagoon Treatment Facilities (evaporative and/or with recycled water irrigation)				
ITEM OR PARAMETER	Units	DESIGN CAPACITY, MGD		
		Minor < 0.10	Minor 0.10 - 1.00	Major >1.0
Total Flow (influent and effluent) ⁷	MGD	Daily or 5 days/week, Measurement		Daily, Measurement by totalizing meter
BOD5 & TSS (influent only)	mg/L	Quarterly or Annual, composite or grab	Monthly, composite	3/week, 24-hr composite
pH (influent & effluent)	standard units	2/week, Grab	3/week, Grab	Daily, Grab
Disinfection: Chlorine				
Chlorine, Total Residual: Effluent when irrigating	mg/L	Daily, Grab		Continuous
Chlorine Residual: Pre De-chlorination ¹⁵	mg/L	Daily, Grab		Continuous
Disinfection: UV				
UV Dose ¹⁶	mJ/cm ²	Daily avg., calculation		
Lagoon Monitoring				
Perimeter Inspection	N/A	Daily or 5 days/week		
Depth of Wastewater per Lagoon	Gauge Units (feet or inches)	Weekly		Daily
Lagoon Solids Accumulation	Record Observations	Once/Permit Cycle		
Biosolids and Recycled Water – See WPCF Permit Template for requirements.				

¹ This matrix is intended for characterization and compliance monitoring; Characterization monitoring provides the permit writer with the best available information to determine reasonable potential to exceed water quality criteria. Compliance monitoring supports permit limits and ensures facility compliance with beneficial uses, water quality based effluent limits, and technology based effluent limits

² Matrix does not include monitoring requirements for recycled water or biosolids. These may be found in the permit template.

³ Deviations from monitoring frequencies must be approved by Direct Support and justification documented in the Fact Sheet. Note that the monitoring frequencies are based on Dry Weather Design Flow. Exceptions may not be made for lower reported flows unless approved.

-
- ⁴ Permittees may request a monitoring reduction if they meet the qualifications stipulated in EPA “Interim Guidance for Performance – Based Reductions of NPDES Permit Monitoring Frequencies - April 19, 1996” memo (<https://www.epa.gov/sites/default/files/2014-08/documents/interim-guidance-for-performance-memo-1996.pdf>). Monitoring may be reduced below what is specified in the monitoring matrix in accordance with Tables 1 and 2 in the memo. Monitoring may not be reduced for any analytes for which the permittee’s receiving water is listed as impaired in the most recent water quality standards Integrated Report.
- ⁵ Consult direct support or management when average dry weather design flow is not available or unknown
- ⁶ When the required monitoring frequency is greater than once during the monitoring period (e.g. 2/week), the permit should specify that monitoring events must be on separate days. When the required monitoring frequency is 2/ month, the monitoring events should be in separate calendar weeks.
- ⁷ Total flow reported is to be representative of flow(s) received, treated and discharged from the facility. In general, the monitoring location should be on both the influent and effluent for facilities with storage such as lagoon treatment systems and on either the influent or the effluent for flow-through facilities. In evaluating the appropriateness of the flow measurement location to characterize the wastewater flows, the permit writer should take into consideration: 1) recirculation flows and diversions which may occur upstream of the flow measurement device, 2) waste streams which may enter the treatment process after the flow measurement device, 3) diversions of the treatment process which occur after the influent measurement device, 4) discharges of effluent to irrigation or other uses which may not be recorded, 5) systems where flow measurement does not account for evaporation and rainfall (lagoons and other storage systems) and 6) systems that have significant off-line storage capacity. It may be necessary to have the permittee submit to DEQ a plan and schedule for implementing the changes necessary to provide accurate flow characterization or evaluate methods and procedures to provide the flow information requested. Note that flow meter calibration is a narrative requirement under Schedule B, item 2.
- ⁸ Frequency of analysis must be the same as it would have been for BOD. See DEQ “*Instruction for BOD5 to CBOD5 Substitution in NPDES Permits*”
- ⁹ When a percent removal limitation for BOD and TSS is required by permittee utilizing septic tanks and the permittee is unable to monitor influent, a 200 mg/ liter assumed influent concentration is to be used in the calculation to credit treatment resulting from the septic tanks.
- ¹⁰ If continuous pH monitoring is allowed, the permit must specify that 1) The permittee must keep on file either daily calibration logs or an instrument manual showing that less than daily calibration is required along with calibration logs that comply with manufacturer instructions and 2) any Proficiency (PT) or Water Pollution (WP) tests must be done using the continuous pH monitor.
- ¹¹ Type of bacteria that is monitored should be consistent with the criteria for the receiving stream. See Bacteria IMD for more information.
- ¹² Frequency of temperature analysis should be the same as pH, except when the facility has water quality based effluent limit based on an excess thermal load calculation, and then sampling may be continuous for minor permittees at the discretion of the permit writer. Temperature monitoring is required even if a permittee does not have a limit for temperature.
- ¹³ If a permittee cannot demonstrate stable ammonia control then increased monitoring of 3/week or more can be required.
- ¹⁴ If permittee is already reporting alkalinity due to other required monitoring (e.g. Copper BLM requirements) then separate alkalinity monitoring is not required.
- ¹⁵ If de-chlorination is used, then total residual chlorine should be monitored pre and post de-chlorination.
- ¹⁶ $UV\ dose = UV\ Intensity \times Residence\ Time.$
- ¹⁷ The POCs (Pollutants of Concern) identified by EPA for pretreatment monitoring are: arsenic, cadmium, chromium, copper, cyanide, lead, mercury, molybdenum, nickel, selenium, silver, zinc, 5 day BOD, TSS and Ammonia (for plants that accept non-domestic sources of ammonia).

-
- ¹⁸ This monitoring is done to develop local limits as well as demonstrate compliance as required in schedule E. The advantage of 3 days is that it can capture variability.
- ¹⁹ Tier I toxics monitoring only needs to occur once over the course of sampling for the WET test.
- ²⁰ While this table explicitly refers to Domestic Permittees, a similar schedule should be used for Industrial Permittees where Priority Pollutants and Copper/Aluminum BLM apply (see EPA Form 2C for industrial monitoring requirements).
- ²¹ If the permittee has a pretreatment program, the permit writer should remove any overlapping parameters testing. However, care should be taken to ensure that the only analytes with overlapping fractions should be removed (e.g. if total recoverable arsenic is being collected for pretreatment then only the requirements for total recoverable arsenic should be removed, the monitoring requirements for inorganic arsenic would remain).
- ²² Toxics may apply in certain circumstances to minor permittees (see RPA IMD). Consult with Direct Support in these cases.
- ²³ 40 CFR 122.21(j)(4)(iv) requires that all POTWs with a design flow rate equal to or greater than 1 MGD must sample and analyze any pollutants for which the state or EPA have established water quality standards applicable to the receiving waters.
- ²⁴ Deviations from monitoring frequencies must be approved by management and justification documented in the Fact Sheet.
- ²⁵ Reporting of BOD and TSS Average Percent Removal Efficiency is only required when the facility discharges.
- ²⁶ Measurements should be taken prior to and during the peak discharge period(s) in the case of seasonal dischargers (e.g. RV parks) or during other critical periods for continuous dischargers.